



SCOTT K. GILMAN
FIRE CHIEF

Lakewood Fire Department • 14601 Madison Avenue • Lakewood, Ohio 44107
Fire Chief 216-529-6658 ← Fire Marshal 216-529-6660 ← Fire Inspector 216-529-6665 ← Administrative Office 216-529-6656
Fax 216-226-9963 ← www.onelakewood.com

August 29, 2011

GUGGENHEIM, INC.
ATTN: MICHAEL A. GUGGENHEIM
23215 COMMERCE PARK DRIVE, SUITE #115
BEACHWOOD, OHIO 44122

Dear Mr. Guggenheim,

On August 15, 2011 a fire safety inspection of the property located at 12019 Lake Avenue, The Day's Inn, was completed. At that time the following items that need correction were noted.

- 1) Remove all combustibles under rear stair closet. 1301-7-7-03(O)(d) 315.2.4
- 2) Remove all extension cords being used as permanent wiring to lights and appliances in all rooms. 1301-7-7-06(E)(5) 605.5
- 3) Laundry chutes shall be equipped with automatic closers. 1301-7-7-07(D)(2) 704.2
- 4) Emergency Exit lighting must be maintained throughout the building in accordance with OFC 1301-7-7-10 (F){B}(3) 1006.3

All work shall be completed within thirty days from the date of this letter. If you have any questions please call me at 529-6660. This was a visual inspection. The City assumes no liability or responsibility for failure to report violations that may exist, and makes no guarantee whatsoever that future violations(s) cannot or will not occur.

Timothy P. Dunphy
Fire Marshal
Lakewood Fire Department

Cc: EMERALD HOSPITALITY ASSOCIATES, INC
ATTN: JEFF MAHONEY
7261 ENGLE ROAD, SUITE #306
MIDDLEBURG HEIGHTS, OHIO 44130